

Outfall Screening Summary

Outfall Name: Drain B-1

Receiving Waters: Boise River via Loggers Creek	Pipe Type: CMP Pipe Size: 46"			Lat: 43.575052 Long: -116.152037	
Date: 06/03/2026 Personnel: JM	Comments:				
Structural Condition	Good				
Sedimentation	None				
Staining	Flow line				
Odor	None				
Vegetation	Typical				
Floatables (Not Trash)	None				
Trash Observed	None	Trash Rank	--	Trash Source	--
Flow	Yes	Amount	Substantial	Flow Rate(cfs)	2.1346

Results:

Temp (C)	DO (mg/L)	pH (S.U.)	Cond (uS/cm)	Chlorine	Copper	Phenols	Turbidity (NTU)
12.12	9.152	8.68	127.7	<0.1	<0.1	<0.1	1.37

E. coli (MPN)	TSS (mg/L)	ORP (mg/L)	Total P (mg/L)	Detergents (mg/L)
185.0	1.77	0.00823	0.0176	0.01

Illicit Discharge?	Unlikely
---------------------------	----------

